

Laboratory and Equipment

Test lab	Moon On Noon
Spectrometer Manufacturer and Model	n/a, n/a – n/a
Measurement date	8/21/2026

Measurement Conditions

Tested c-planes	8
Tested gamma angles	181 – 1.00°
Input Power	2.89 W


Tested Light Source

Luminaire	MON-SR2203-N
Basic Luminous Shape	PANEL
Item No.	
Manufacturer	Moon On Noon


Main Light Measurement Results

Output – Total Lumen (Up% / Down%)	52.72 lm – 0% / 100%
Efficiency	18.24 lm/W
Peak Intensity	34.14 cd
Correlated Color Temperature, CCT	3000 K
Color Rendering Index	CRI 85.0

Polar light distribution diagram




Beam details




Luminaire budgetary diagram


LAMPS (number of lamps)




Iso-intensity Diagram (Iso-candela)



Iso-illuminance Diagram (Iso-lux)




Linear intensity distribution diagram



IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

BUG rating B0 U0 G0



Forward Light

Low (0-30°)	9.4 lm	17.8%
Medium (30-60°)	18.3 lm	34.7%
High (60-80°)	3.5 lm	6.7%
Very High (80-90°)	0.3 lm	0.6%

Back Light

Low (0-30°)	7.3 lm	13.9%
Medium (30-60°)	10.9 lm	20.6%
High (60-80°)	2.8 lm	5.2%
Very High (80-90°)	0.3 lm	0.5%

Uplight

Low (90-100°)	0.0 lm	0.00%
High (100-180°)	0.0 lm	0.0%

Total

Sum	52.7 lm	100,0%
-----	---------	--------